



Addendum No. 3
Request for Proposals (RFP) No. 16-31
Water Tank Maintenance

October 26, 2016

RFP No. 16-31 is hereby amended as follows:

1. Below are questions received and corresponding answers:

A. Question: What is the date each tank was coated?

1. Sweetheart Tank
2. Maxcel
3. Bio Lab
4. Lorraine

Answer: See below.

1. Sweetheart Tank – around 2010
2. Maxcel - 2014
3. Bio Lab – June 2004 after the Bio-Lab fire in Conyers, GA
4. Lorraine – Has its original production coat of 2001

B. Question: What is the date the Lorraine tank was built?

Answer: 2001.

C. Question: What is the height to top and height to bottom of the Lorraine tank?

Answer: Height to high water level: 73' – 0"
Height to low water level: 34' – 6"

D. Question: What is the capacity of the Lorraine tank?

Answer: 1,000,000 gallons.

Board of Commissioners

Richard A. Oden, Chairman

Oz Nesbitt, Sr., Commissioner

Dr. Doreen Williams, Commissioner



Department of Finance

Telephone: 770-278-7555

Facsimile: 770-278-8910

2. All other conditions remain in full force and effect.
3. If a proposal has been submitted and anything in this Addendum causes the bidder to change the item offered or to increase or decrease the proposal price, the new price and/or changes will be inserted below:

4. All proposers under this RFP are kindly requested to acknowledge receipt of this Addendum on page 13, Part II of the Proposal Form.

Tina Malone

Tina Malone, CPPB CPPO

Procurement Officer

Department of Finance, Purchasing Division